

Manitou Web Client: Late-To-Test transmitters

Manitou Web Client can display a list of all **Late-To-Test** transmitters. A **Late-To-Test** signal indicates that the alarm panel on the customer side may not be able to communicate signals any further. This may be due to a power issue, an alarm panel problem, or other issues. This information was also available in the Manitou Legacy Client by navigating to Maintenance > Monitoring Company > Statistics.

Standard Dashboard

On the Standard Dashboard, locate the statistics section. Scroll down to the Customer TX Summary. Locate the **TX With Late-To-Test** row. Clicking on the link will display a list of all customers that have at least one transmitter with a Late-To-Test status.

| Customer TX Summary | |
|-------------------------------|---------------|
| TX In Alarm: | 1 |
| TX In Fault: | 0 |
| TX In Line Fault: | 0 |
| TX With Low Battery: | 1 |
| TX With Late-To-Test: | 6 |
| TX Missing Event Programming: | 6 |
| TX Not On File In The Last | 24 ▼ hours: 0 |